

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2
No. Hom (FS) (HQ)6-10/76-XL-Sml, N.O.C. dated 11/08/2017 Shimla-2

TO WHOM IT MAY CONCERN

That the premises of Kendriya Vidyalaya Mandi, Distt. Mandi was inspected on 06-07-2017 with reference to his application No. Nil dated 01-07-2017 by the Incharge, Fire Station Mandi with regard to measures adopted for protection against fire and it has been reported/ recommended.

That the first aid fire fighting measures adopted by the above applicant in school were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for two years (i.e 10-08-2017 to 09-08-2019) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/ operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintained the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire Precautionary measures be adopted in the consultation with local Fire Officer during annual day function or any other function in the School where temporary structures and Pandals are to be erected.

11/8/17
Koushik

व्यक्तिगत
आपका काम कर रहा है

To
The Principal,
Kendriya Vidyalaya Mandi,
Distt. Mandi H.P.

17/8/17
A. Sharma
Chief Fire Officer,
Himachal Pradesh Shimla-2